

Wastewater Discharge Limitations And Monitoring Requirement

Parameter	Local Limits	Units
Temperature	40	°C
pH	5 – 9	S.U.
CBOD	485	mg/L
TSS	698	mg/L
Ammonia	59.21	mg/L
Oil & Grease	100	mg/L
Toluene	N/A	mg/L
Flash Point	>140	°F
Arsenic	0.51	mg/L
Cadmium	0.38	mg/L
Chromium (Total)	1.86	mg/L
Chromium (Hex)	0.31	mg/L
Copper	0.49	mg/L
Cyanide	0.27	mg/L
Lead	5.56	mg/L
Mercury	0.002	ng/L
Moylbdenum	None	mg/L
Nickel	1.57	mg/L
Selenium	1.01	mg/L
Silver	0.31	mg/L
Zinc	0.90	mg/L