



**LIMITS OF PAYMENT:**

PAYMENT SECTION IS 'W' x 'H'

THE TOP LIMIT OF 'H' IS THE BOTTOM OF PAVEMENT, BOTTOM OF BERM AGGREGATE BASE, TOP OF TRENCH, OR REQUIRED ELEVATION (WHERE THE TRENCH IS ONLY PARTIALLY BACKFILLED WITH GRANULAR BACKFILL).

THE BOTTOM LIMIT OF 'H' IS THE TOP OF THE GRANULAR BEDDING MATERIAL ACCORDING TO SD-116 OR SD-117 AS APPROPRIATE.

**NOTES:**

DUCTILE IRON WATER PIPE SHALL HAVE A MINIMUM OF 12" OF SAND GRANULAR BEDDING ABOVE AND BELOW THE INSTALLED WATER PIPE.

USE STONE FOUNDATION WHEN THE NATURAL FOUNDATION PROVES UNSUITABLE AS DETERMINED BY THE RESIDENT PROJECT REPRESENTATIVE AND IN ACCORDANCE WITH THE SPECIFICATIONS.

<b>CITY OF NEW PHILADELPHIA</b>		STANDARD CONSTRUCTION DRAWING NO. <b>SD-106</b> REV. 03-13
GRANULAR BACKFILL DETAIL FOR TRENCH		